N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17170-73-0913
State Number
15559

EQUIPMENT INSPECTED

State Number: **15559**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 05/04/1995	Rope Size:
Volts: 480	Complied: 05/04/1995	Entrances: 1

OWNER	OCCUPANT
GRAHAM LIBRARY & POLICE BLDG	GRAHAM LIBRARY & POLICE BLDG
201 S MAIN STREET	201 S MAIN STREET
GRAHAM, NC, 27253	GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/19/2017	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6 Provide in case of fire sign at each landing

Items must be corrected by: 08/18/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: sclayton@cityofgraham.com Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
GRAHAM LIBRARY & POLICE BLDG
201 S MAIN STREET
GRAHAM, NC, 27253