



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17180-48-0331
State Number
25607

EQUIPMENT INSPECTED

State Number: **25607**

Capacity: 2000

Landings: 3

Volts: 208

Type of Unit: Passenger

Manuf: TKE

Installed: 09/26/2008

Complied: 09/26/2008

Floor to Floor: 1 to 3

Speed: 125

Rope Size:

Entrances: 1

OWNER

VILLAGE PARK PROPERTY OWNERS ASSOCIATION

1482 BANKING ST.

GREENSBORO, NC, 27408

OCCUPANT

VILLAGE PARK CONDOS

7821 HIGH MARKET STREET

SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date
06/29/2017

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
48 - Martin

County
BRUNSWICK

10

VIOLATIONS

- 2.8.1 Only machinery and equipment used directly in connection with the elevator shall be permitted in elevator hoistways, machinery spaces, machine rooms, control spaces, and control rooms.
- 8.6.4.8 Clean the machine room and the machine room equipment.

Items must be corrected by: 07/29/2017

Elevator Name: BLDG 4 ELEV 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

VILLAGE PARK PROPERTY OWNERS ASSOCIATION
1482 BANKING ST.
GREENSBORO, NC, 27408