



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17184-73-2358
State Number
16229

EQUIPMENT INSPECTED

State Number: 16229	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 03/07/1996	Rope Size:
Volts: 208	Complied: 03/07/1996	Entrances: 1
OWNER	OCCUPANT	
UNIVERSAL FOREST PRODUCTS	UNIVERSAL FOREST PRODUCTS	
5631 SOUTH NC 62	5631 SOUTH NC 62	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.2.5.1	Place the pit lights in working order. 100 lx or 10 fc @ the pit floor.
2.27.1.1.1	Place the in-car Emergency Phone in working order.

Items must be corrected by: 09/01/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: jthompson@ufpi.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

UNIVERSAL FOREST PRODUCTS
5631 SOUTH NC 62
BURLINGTON, NC, 27215