N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
**17184-73-3657**
State Number
**23486**

## EQUIPMENT INSPECTED

State Number: **23486**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 09/22/2005
Complied: 09/26/2005

Floor to Floor: 1 to 2
Speed: 95
Rope Size:
Entrances: 1

OWNER
JR OUTLET MALL
2589-A ERIC LANE
BURLINGTON, NC, 27215

OCCUPANT
JR OUTLET MALL
2589-A ERIC LANE
BURLINGTON, NC, 27215

## INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County |
|---|---|---|---|---|
| 07/03/2017 | Routine | Re-issued | 73 - James | ALAMANCE |

1

## VIOLATIONS

2.7.9.1 Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.
8.6 provide current inspection class abc fire exstinguisher in machine room

Items must be corrected by: 09/01/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: jcapes@mcmail.cc

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
JR OUTLET MALL
2589-A ERIC LANE
BURLINGTON, NC, 27215