

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 17184-76-3019 State Number 11204

	EQI	UIPMENT INSPECTED			
State Number: 11204 Capacity: 2100	• •	Type of Unit: Passenger Manuf: THYSSEN KRUPP		Floor to Floor: 1 to 3 Speed: 100	
Landings: 3		Installed: 07/25/1985		Rope Size: Entrances: 1	
Volts: 220	Complied: 07/25/198	Complied: 07/25/1985			
OWNER		OCCUPANT	T. D. D. J.		
THE GREYSTONE INN 2663 ROARING GAP DR.		THE GREYSTONE INN 2663 ROARING GAP DR. ROARING GAP NC, NC, 28668			
ROARING GAP NC, NC, 28	3668				
	INSPI	ECTION INFORMATION			
Inspection Date 07/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ALLEGHANY	
		VIOLATIONS			
8.6.11.1 Provide a monthly 2.29.1 Assign identificatio 8.6.1.6.5 Provide a NBCC C 2.7.9.1 Place the machine in	oility verification means in working order, log on the results of the Phase I and Phase on numbers or letters to the equipment who class ABC fire extinguisher convienent to room or space lights in working order. Light ire Service feature in proper working order.	e II operations. Here required. "Do Not Use In the access door in the maching this need to be protected."	=	at each floor	
Items must be corrected by Notify the Elevator Bureau in v complainace with current codes Violations pointed out to: gary	writing on Corrected Violations Form whos. Adins 336-363-2211	en the following corrections h		oring your equipment into	