



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17184-76-4013**  
State Number  
**H1805**

EQUIPMENT INSPECTED

State Number: <b>H1805</b>	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 10
Landings: 2	Installed: 11/21/2006	Rope Size: 0
Volts: 120	Complied: 11/21/2006	Entrances: 2
OWNER	OCCUPANT	
ALLEGHENY COUNTY	ALLEGHENY COUNTY COURT HOUSE	
348 S MAIN STREET	12 N MAIN STREET	
SPARTA, NC, 29063	SPARTA, NC, 29063	

INSPECTION INFORMATION

Inspection Date 07/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ALLEGHENY
-------------------------------	----------------------------	---------------------------------	-------------------------	---------------------

3

VIOLATIONS

2.14.7.1.3 Place the in-car emergency lights in working order. The auxillary lighting illumination shall not be less than 2 lx (0.2 fc) measured at any point between 48 in. and 35 in. above the car floor and approximately 12 in. centered horizontally in front o

Items must be corrected by: 08/02/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Josh Greene 336-372-010

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLEGHENY COUNTY  
348 S MAIN STREET  
SPARTA, NC, 29063