



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17184-76-4612
State Number
7648

EQUIPMENT INSPECTED

State Number: 7648	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1500	Manuf: SOUTHERN	Speed: 100
Landings: 2	Installed: 09/09/1973	Rope Size:
Volts: 480	Complied: 09/12/1973	Entrances: 1
OWNER	OCCUPANT	
ALLEGHANY COUNTY	ALLEGHANY COUNTY JAIL	
348 S MAIN ST	N MAIN ST	
SPARTA, NC, 28675	SPARTA, NC, 28675	

INSPECTION INFORMATION

Inspection Date 07/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	-------------------------	---------------------

3

VIOLATIONS

- 2.7.9.1 Place the machine room or space lights in working order. Light needs to be protected
- 5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.
- 2.29.1 Assign identification numbers or letters to the equipment where required. Door needs to be identified as "Elevator Machine Room, Authorized Personnel Only" sign
- 8.6.1.6.5 Provide a NBCC Class ABC fire extinguisher convenient to the access door in the machine room / space.
- 2.7.3.4.1 Provide a self closing self-locking machine room / space door.

Items must be corrected by: 08/02/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Josh Greene 336-372-2010

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLEGHANY COUNTY
348 S MAIN ST
SPARTA, NC, 28675