



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17186-48-0529
State Number
26864

EQUIPMENT INSPECTED

State Number: 26864	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: TKE	Speed: 55
Landings: 3	Installed: 07/21/2009	Rope Size:
Volts: 230	Complied: 07/21/2009	Entrances: 1
OWNER	OCCUPANT	
INLET VIEW BAR & GRILL	INLET VIEW BAR & GRILL	
1800 VILLAGE POINT RD	1800 VILLAGE POINT ROAD	
SHALLOTTE, NC, 28470	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 07/05/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.2.5.1 Place the pit lights in working order. 100 lx or 10 fc @ the pit floor.

Items must be corrected by: 08/04/2017

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SAMATHA

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

INLET VIEW BAR & GRILL
1800 VILLAGE POINT RD
SHALLOTTE, NC, 28470