



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17186-73-2535
State Number
849

EQUIPMENT INSPECTED

State Number: 849	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 3000	Manuf: MONARCH	Speed: 75
Landings: 3	Installed: 11/05/1946	Rope Size: 1/2
Volts: 220	Complied: 11/05/1946	Entrances: 2
OWNER RYAN SCOTT PROPERTIES LLC PO BOX 38785 GREENSBORO, NC, 27438	OCCUPANT MAIN & FIFTH 216 E FRONT ST BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/05/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.3.4	Replace the governor rope.
A 17.6 - 1.10.1	Replace the hoist ropes.
8.1.1.(c)	Provide machine room keys on premises. Keys shall be kept on the premises in a location readily accessible to elevator personnel but not where they are accessible to the general public.
8.6.4.7	Clean the pit and the pit equipment.

Items must be corrected by: 09/03/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: mcclinto7@aol.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RYAN SCOTT PROPERTIES LLC
PO BOX 38785
GREENSBORO, NC, 27438