

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 17186-73-3258 State Number 17516

EQUIPMENT INSPECTED

State Number: 17516	Type of Unit: Passenger	Floor to Floor: B to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 07/21/1998	Rope Size:
Volts: 208	Complied: 07/21/1998	Entrances: 1
OWNER	OCCUPANT	
B D DIAGNOSTICS	B D DIAGNOSTICS	
780 PLANTATION DR	780 PLANTATION DR	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/05/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: devie_ingold@bd.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

B D DIAGNOSTICS
780 PLANTATION DR
BURLINGTON, NC, 27215