N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17186-73-3428
State Number
26694

EQUIPMENT INSPECTED

State Number: **26694**
Capacity: 2100
Landings: 2
Volts: 200

Type of Unit: Passenger
Manuf: TKE
Installed: 07/13/2009
Complied:

Floor to Floor: 1 to 2
Speed: 110
Rope Size:
Entrances: 2

OWNER
CITY OF MEBANE
160 E WASHINGTON ST
MEBANE, NC, 27302

OCCUPANT
MEBANE OLD RECREATION CENTER
210 LEE ST
MEBANE, NC, 27302

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/05/2017	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order. (location not known)

Items must be corrected by: 09/03/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: sshaw@cityofmebane.com

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CITY OF MEBANE
160 E WASHINGTON ST
MEBANE, NC, 27302