



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17187-73-1287
State Number
19840

EQUIPMENT INSPECTED

State Number: 19840	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 04/06/2001	Rope Size:
Volts: 200	Complied: 04/06/2001	Entrances: 1
OWNER	OCCUPANT	
B.C. PARKER REAL ESTATE	DELANEY CROSSING	
336-226-8411	2225 DELANEY ST	
GREENSBORO, NC, 27408	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/06/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 09/04/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Brandy

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

B.C. PARKER REAL ESTATE
336-226-8411
GREENSBORO, NC, 27408