



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17187-73-1871
State Number
19412

EQUIPMENT INSPECTED

State Number: 19412	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 08/01/2000	Rope Size:
Volts: 200	Complied: 08/01/2000	Entrances: 1
OWNER	OCCUPANT	
B.C. PARKER REAL ESTATE	DELANEY CROSSING BLDG #1	
336-226-8411	2221 DELANEY DR	
BURLINGTON, NC, 27429	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/06/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.13.1(i)	Place the door restrictor in proper working order.
2.7.3.4.1	Provide a self closing self-locking machine room / space door.
8.6	Place in case of fire sign at each landing

Items must be corrected by: 09/04/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: brandy@bcparker.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

B.C. PARKER REAL ESTATE
336-226-8411
BURLINGTON, NC, 27429