N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17187-73-2449
State Number
18757

EQUIPMENT INSPECTED

State Number: **18757**
Capacity: 2500
Landings: 3
Volts: 200

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 04/20/2000
Complied: 04/20/2000

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
B.C. PARKER REAL ESTATE
336-226-8411
GREENSBORO, NC, 27429

OCCUPANT
DELANEY CROSSING #6
2219 DELANEY DR
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/06/2017	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

2.7.3.4.1 Provide a self closing self-locking machine room / space door.

Items must be corrected by: 09/04/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: brandy

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
B.C. PARKER REAL ESTATE
336-226-8411
GREENSBORO, NC, 27429