

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 17187-73-5816 State Number 19643

EQUIPMENT INSPECTED

State Number: 19643	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 01/05/2001	Rope Size:
Volts: 200	Complied: 01/05/2001	Entrances: 1
OWNER	OCCUPANT	
B.C. PARKER REAL ESTATE	DELANEY CROSSING #2	
336-226-8411	2223 DELANEY DR	
GREENSBORO, NC, 27429	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/06/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

VIOLATIONS

- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 8.6 Place in case of fire sign at each landing

Items must be corrected by: 09/04/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Brandy

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372
An invoice will be mailed to:
B.C. PARKER REAL ESTATE
336-226-8411
GREENSBORO, NC, 27429