



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17187-75-0274
State Number
H2705

EQUIPMENT INSPECTED

State Number: H2705	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 17
Landings: 2	Installed: 10/08/2015	Rope Size:
Volts: 120	Complied: 10/08/2015	Entrances: 2
OWNER	OCCUPANT	
AB TECH COMMUNITY COLLEGE	AB TECH COMM COLLEGE MULTI PURPOSE BLDG	
340 VICTORIA ROAD	340 VICTORIA ROAD	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 07/06/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 08/05/2017

Elevator Name: handicap lift

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Ellen Ryan 828398-7901

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECH COMMUNITY COLLEGE
340 VICTORIA ROAD
ASHEVILLE, NC, 28801