



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17192-76-5871
State Number
11828

EQUIPMENT INSPECTED

State Number: 11828	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 10/01/1986	Rope Size:
Volts: 240	Complied: 10/01/1986	Entrances: 1
OWNER	OCCUPANT	
ALLEGHANY COUNTY	ALLEG CO / SR CITIZEN CTR	
348 S MAIN STREET	MAIN ST	
SPARTA, NC, 28675	SPARTA, NC, 28675	

INSPECTION INFORMATION

Inspection Date 07/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	-------------------------	---------------------

3

VIOLATIONS

- 2.29.1 Assign identification numbers or letters to the equipment where required. Elevator machine room door needs a "Elevator Room, Authorized Personnel Only" sign on the door
- 2.7.3.4.1 Provide a self closing self-locking machine room / space door.
- 8.6.1.6.5 Provide a NBCC Class ABC fire extinguisher convenient to the access door in the machine room / space.

Items must be corrected by: 08/10/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Alleghany Adult center 336-372-2010

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLEGHANY COUNTY
348 S MAIN STREET
SPARTA, NC, 28675