



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17193-48-2046
State Number
24641

EQUIPMENT INSPECTED

State Number: 24641	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: TKE	Speed: 95
Landings: 2	Installed: 06/05/2007	Rope Size: 0
Volts: 208	Complied: 06/05/2007	Entrances: 1
OWNER	OCCUPANT	
SEA SCAPE POA	CLUBHOUSE AT SEASCAPE	
PO BOX 6894	700 LAGARE LN. SW.	
OCEAN ISLE, NC, 28469	HOLDEN BEACH, NC, 28462	

INSPECTION INFORMATION

Inspection Date 07/12/2017	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A PROVIDE ACCESS TO BLDG.

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEA SCAPE POA
PO BOX 6894
OCEAN ISLE, NC, 28469