



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17193-48-4541**  
State Number  
**21154**

EQUIPMENT INSPECTED

State Number: <b>21154</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 09/24/2002	Rope Size: 0
Volts: 480	Complied: 09/24/2002	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK CO. BOARD OF EDUC.	W. BRUNSWICK HIGH SCHOOL	
35 REFREEDOM DRIVE	550 WHITEVILLE RD., NW	
BOLIVIA, NC, 28422	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 07/12/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.19.2 (b)	Provide the annual no load test.
N/A	REPAIR CAR DOOR [STICKING ON 2ND. FL.]

Items must be corrected by: 08/11/2017

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK CO. BOARD OF EDUC.  
35 REFREEDOM DRIVE  
BOLIVIA, NC, 28422