



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17194-48-3532**  
State Number  
**27440**

EQUIPMENT INSPECTED

|                                |                            |                        |
|--------------------------------|----------------------------|------------------------|
| State Number: <b>27440</b>     | Type of Unit: Passenger    | Floor to Floor: 1 to 2 |
| Capacity: 3500                 | Manuf: SCHINDLER           | Speed: 100             |
| Landings: 2                    | Installed: 08/25/2010      | Rope Size:             |
| Volts: 208                     | Complied: 08/25/2010       | Entrances: 1           |
| OWNER                          | OCCUPANT                   |                        |
| ARBOR LANDING @ OCEAN ISLE LLC | ARBOR LANDING @ OCEAN ISLE |                        |
| 853 OLD WINSTON RD STE 118     | 5521 BEECH DRIVE NW        |                        |
| KERNERSVILLE, NC, 27284        | OCEAN ISLE, NC, 28469      |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                          |                     |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date<br>07/13/2017 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>48 - Martin | County<br>BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

8.6.4.7 Remove oil from the pit floor

Items must be corrected by: 08/12/2017

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: S. MCCUMBEE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARBOR LANDING @ OCEAN ISLE LLC  
853 OLD WINSTON RD STE 118  
KERNERSVILLE, NC, 27284