



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17198-73-2254
State Number
11235

EQUIPMENT INSPECTED

State Number: 11235	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 4000	Manuf: SOUTHERN	Speed: 150
Landings: 4	Installed: 05/20/1986	Rope Size:
Volts: 460	Complied: 06/24/1986	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE CO. JAIL	ALAMANCE CO. JAIL	
ELM STREET	ELM STREET	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 07/17/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.5.5.2	Empty the drain bucket in the pit.
8.6.4.7	Remove oil from the pit floor
8.6.4.13.1(i)	Place the door restrictor in proper working order.
8.6.4.7	Clean the pit and the pit equipment.
2.27.1.1.1	Place the in-car Emergency Phone in working order.
8.6.1.6.5	Provide a class ABC fire extinguisher in the machinery space.
8.6.4.7	Clean the pit and the pit equipment.

Items must be corrected by: 09/15/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE CO. JAIL
ELM STREET
GRAHAM, NC, 27253