



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17198-73-2826
State Number
14972

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 14972 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2500 | Manuf: THYSSEN KRUPP | Speed: 100 |
| Landings: 2 | Installed: 11/19/1993 | Rope Size: |
| Volts: 460 | Complied: 12/08/1993 | Entrances: 1 |
| OWNER | OCCUPANT | |
| ALAMANCE COUNTY | CRIMINAL COURTS BLDG | |
| 124 W ELM ST | W ELM ST | |
| GRAHAM, NC, 27253 | GRAHAM, NC, 27253 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date 07/17/2017 | Type Inspection Routine | Certificate Status Re-issued | Inspector 73 - James | County ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

1

VIOLATIONS

| | |
|------------|---|
| 8.6.1.6.5 | Provide a class ABC fire extinguisher in the machinery space. |
| 8.6.5.14.1 | Provide the annual relief valve and hydraulic system pressure test. |
| 2.27.1.1.1 | Place the in-car Emergency Phone in working order. |

Items must be corrected by: 09/15/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAMANCE COUNTY
124 W ELM ST
GRAHAM, NC, 27253