



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17198-73-4576
State Number
13818

EQUIPMENT INSPECTED

State Number: 13818	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 5	Installed: 05/29/1990	Rope Size:
Volts: 460	Complied: 05/31/1990	Entrances: 2
OWNER	OCCUPANT	
ALAMANCE CO. COURT	ALAMANCE CO. COURT	
124 WEST ELM STREET	124 W. ELM STREET	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 07/17/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
8.6	Provide missing certificate frame screw

Items must be corrected by: 09/15/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE CO. COURT
124 WEST ELM STREET
GRAHAM, NC, 27253