



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17200-48-0272**  
State Number  
**28840**

EQUIPMENT INSPECTED

State Number: <b>28840</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 110
Landings: 3	Installed: 07/11/2013	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
WESTGATE SENOIR APTS	WESTGATE SENOIR LIVING ELEV 1	
9200 OCEANGATE PLAZA EXT	9200 OCEANGATE PLAZA EXT	
LELAND, NC, 28541	LELAND, NC, 28541	

INSPECTION INFORMATION

Inspection Date 07/19/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7 Clean the pit and the pit equipment.

Items must be corrected by: 08/18/2017

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Fred

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WESTGATE SENOIR APTS  
9200 OCEANGATE PLAZA EXT  
LELAND, NC, 28541