



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17205-73-1110
State Number
H615

EQUIPMENT INSPECTED

State Number: H615	Type of Unit: Hand Lift	Floor to Floor: G to 1
Capacity: 750	Manuf: NATL W-O-V	Speed: 9
Landings: 2	Installed: 12/30/1994	Rope Size:
Volts: 110	Complied: 01/03/1995	Entrances: 2
OWNER		OCCUPANT
ALAMANCE - BURLINGTON SCHOOL SYSTEM		WILLIAMS HIGH SCHOOL
1712 VAUGHAN RD		1307 S CHURCH ST
BURLINGTON, NC, 27215		BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 07/24/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6 Replace missing stop switch on platform

Items must be corrected by: 09/22/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE - BURLINGTON SCHOOL SYSTEM
1712 VAUGHAN RD
BURLINGTON, NC, 27215