



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17205-73-5785
State Number
18087

EQUIPMENT INSPECTED

State Number: 18087	Type of Unit: Passenger	Floor to Floor: 1F to 1R
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 03/10/1999	Rope Size:
Volts: 480	Complied: 03/10/1999	Entrances: 2
OWNER	OCCUPANT	
NATIONAL SPINNING CO INC	NATIONAL SPINNING CO INC	
226 GLEN RAVEN RD	226 GLEN RAVEN RD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/24/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.

Items must be corrected by: 09/22/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Manager

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NATIONAL SPINNING CO INC
226 GLEN RAVEN RD
BURLINGTON, NC, 27215