



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17207-73-4037
State Number
7551

EQUIPMENT INSPECTED

State Number: 7551	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: WESTBROOK	Speed: 75
Landings: 3	Installed: 07/20/1973	Rope Size: 1/2
Volts: 460	Complied: 07/20/1973	Entrances: 1
OWNER	OCCUPANT	
BURLINGTON IND	BURLINGTON IND	
615 W HARDEN ST	615 W HARDEN ST	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 07/26/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.11.11.5	Repair the damaged hoistway doors. Make open all the way on there own
2.11.2.8	Replace the missing pull straps.
8.6.4.20.1	Provide the 5 year full load test.
8.6.4.7	Clean the pit and the pit equipment.

Items must be corrected by: 09/24/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BURLINGTON IND
615 W HARDEN ST
GRAHAM, NC, 27253