



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17207-73-4073
State Number
8209

EQUIPMENT INSPECTED

State Number: 8209	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 12/16/1975	Rope Size:
Volts: 208	Complied: 12/09/2002	Entrances: 1

OWNER

ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE KERR ROAD
GRAHAM, NC, 27253

OCCUPANT

ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE-KERR ROAD
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 07/26/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.1.4.1 Provide an updated Firefighters Emergency Operation log. (Monthly)

Items must be corrected by: 09/24/2017

Elevator Name: MAIN BLDG #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE KERR ROAD
GRAHAM, NC, 27253