



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17208-48-229**  
State Number  
**25786**

EQUIPMENT INSPECTED

State Number: <b>25786</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: SCHINDLER	Speed: 150
Landings: 3	Installed: 08/06/2008	Rope Size:
Volts: 480	Complied: 08/06/2008	Entrances: 2
OWNER	OCCUPANT	
BRUNSWICK CO COURTHOUSE #5	BRUNSWICK CO. SANDIFER BLDG	
P.O. BOX 249	30 GOVERNMENT CENTER DRIVE	
BOLIVIA, NC, 28422	BOLIVIA, NC, 28422	

INSPECTION INFORMATION

Inspection Date 07/27/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7	Remove oil from the pit floor
2.27.1.1.1	Place the in-car Emergency Phone in working order.

Items must be corrected by: 08/26/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JERRY

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK CO COURTHOUSE #5  
P.O. BOX 249  
BOLIVIA, NC, 28422