



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17214-75-1579
State Number
15618

EQUIPMENT INSPECTED

State Number: 15618	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/28/1995	Rope Size:
Volts: 208	Complied: 07/25/1995	Entrances: 1
OWNER	OCCUPANT	
AB TECHNICAL COLLEGE	AB TECHNICAL COLLEGE/LIBRARY	
340 VICTORIA RD	340 VICTORIA RD	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 08/02/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

8.11.3.2.1	Perform the annual relief valve test
NEC	Guard machine room lights.

Items must be corrected by: 10/01/2017

Elevator Name: 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Billy Warren 828-774-7939

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECHNICAL COLLEGE
340 VICTORIA RD
ASHEVILLE, NC, 28801