



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17214-75-1994
State Number
9563

EQUIPMENT INSPECTED

State Number: 9563	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: ASHEVILLE	Speed: 125
Landings: 3	Installed: 05/05/1980	Rope Size:
Volts: 480	Complied: 06/04/1980	Entrances: 1
OWNER	OCCUPANT	
AB TECHNICAL COLLEGE	AB TECHNICAL COLLEGE/ ELM	
340 VICTORIA RD	340 VICTORIA RD	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 08/02/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

2.13.5.1 Put the car door reopening devices in proper working order. (electric eyes inop.when cab lights turned off.)

Items must be corrected by: 10/01/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Billy Warren 828-774-7939

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECHNICAL COLLEGE
340 VICTORIA RD
ASHEVILLE, NC, 28801