



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17215-48-472
State Number
17013

EQUIPMENT INSPECTED

State Number: 17013	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 150
Landings: 4	Installed: 11/24/1997	Rope Size:
Volts: 480	Complied: 01/09/1998	Entrances: 1
OWNER	OCCUPANT	
BENCHMARK MANAGEMENT	WINDJAMMER CONDO	
C/O JANE WHIELDON	27 W 2ND ST	
NORTH MYRTLE BEACH, SC, 29597	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 08/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

5.1.21.1	Place the car alarm bell in working order. Minimum level of 80 dBA.
8.6.4.7	Clean the pit and the pit equipment.
2.27.1.1.1	Place the in-car Emergency Phone in working order.

Items must be corrected by: 10/02/2017

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BENCHMARK MANAGEMENT
C/O JANE WHIELDON
NORTH MYRTLE BEACH, SC, 29597