



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17215-75-0138
State Number
21935

EQUIPMENT INSPECTED

State Number: 21935	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: SCHINDLER	Speed: 125
Landings: 3	Installed: 11/10/2003	Rope Size: 0
Volts: 480	Complied: 11/10/2003	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE BUNCOMBE TECH	ASHEVILLE BUNCOMBE TECH/BALSAM	
340 VICTORIA RD	COMPUTER TECH BLDG	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 08/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

8.6.1.6.3	Clean the controller and its components.(Take steps to prevent oil in the controller.)
8.6.1.6.5	Provide the required fire extinguisher in the machine room.
8.6.5.16.5	Perform 5 year test on overspeed valve.(seal is broken.)

Items must be corrected by: 10/02/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Billy Warren 828-774-7939

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ASHEVILLE BUNCOMBE TECH
340 VICTORIA RD
ASHEVILLE, NC, 28801