



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17215-75-0168**  
State Number  
**8834**

EQUIPMENT INSPECTED

State Number: <b>8834</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: ASHEVILLE	Speed: 125
Landings: 2	Installed: 05/27/1977	Rope Size:
Volts: 208	Complied: 11/09/1995	Entrances: 1

OWNER

AB TECH COLLEGE /LIBRARY  
340 VICTORIA ROAD  
ASHEVILLE, NC, 28801

OCCUPANT

AB TECH COLLEGE /LIBRARY  
340 VICTORIA ROAD  
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 08/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
5.1.21.1	Put the in car alarm bell in working order.

Items must be corrected by: 10/02/2017

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Billy Warren 828-774-7939

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECH COLLEGE /LIBRARY  
340 VICTORIA ROAD  
ASHEVILLE, NC, 28801