



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17215-75-2260
State Number
13037

EQUIPMENT INSPECTED

State Number: 13037	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 05/16/1989	Rope Size:
Volts: 240	Complied: 05/25/1989	Entrances: 1
OWNER	OCCUPANT	
A B TECHNICAL COLLEGE IND ED BLDG	A B TECHNICAL COLLEGE/DOGWOOD	
340 VICTORIA RD	340 VICTORIA RD	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 08/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

- 8.6.4.7.4 Remove the oil from the pit floor.
- 8.6.5.7 Provide an oil usage log in the machine room recording the quantity of hydraulic fluid added to the system and emptied from leakage catch pan and containers.
- 2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 10/02/2017

Elevator Name: dogwood

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Billy Warren 828-774-7939

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

A B TECHNICAL COLLEGE IND ED BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801