

## N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

## INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 17215-75-5764 State Number 9951

		EQUIPMENT INSPECTED	)		
State Number: 9951  Capacity: 2000  Landings: 2  Volts: 230  OWNER  AB TECH COLLEGE /BIRCH BLDG  340 VICTORIA RD  ASHEVILLE, NC, 28801		UTHERN 5/23/1981	Floor to Floo Speed: 125 Rope Size: Entrances: 1	r: 1 to 2	
		OCCUPANT AB TECH COLLEGE /BIRCH BLDG 340 VICTORIA RD ASHEVILLE, NC, 28801			
		INSPECTION INFORMATIO	)N		
Inspection Date 08/03/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
		VIOLATIONS			
6.0.1.0.3 Flovide the required	fire extinguisher in the machine	IOOIII.			
Items must be corrected by: 10/02/2017			Elevator Name: birch		
Notify the Elevator Bureau in w complainace with current codes		Form when the following correcti	ons have been made in order	to bring your equipment i	nto
Violations pointed out to: Billy	Warren 828-774-7939		Inspector		
To make changes to the invoice mailing address please call: 919-733-0372  THIS IS NOT AN  AB TECH COLLEGE /BIRCH BLDG  INVOICE  An invoice will be mailed to: 340 VICTORIA RD  ASHEVILLE, NC, 28801					