



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17216-75-2360
State Number
16329

EQUIPMENT INSPECTED

State Number: 16329	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 02/15/1996	Rope Size:
Volts: 208	Complied: 02/15/1996	Entrances: 1
OWNER	OCCUPANT	
AB TECH	AB TECH	
340 VICTORIA RD.	93 VICTORIA RD.	
AHSEVILLE, NC, 28801	AHSEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 08/04/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

8.6.5.7	Provide an oil usage log in the machine room.
8.6.1.6.5	Provide a class ABC fire extinguisher in the machinery space.
NEC	Guard machine room lights.

Items must be corrected by: 10/03/2017

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Billy Warren 828-774-7939

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECH
340 VICTORIA RD.
AHSEVILLE, NC, 28801