



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17226-48-543
State Number
27279

EQUIPMENT INSPECTED

State Number: 27279	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 130
Landings: 2	Installed: 09/20/2010	Rope Size:
Volts: 208	Complied: 09/20/2010	Entrances: 1
OWNER	OCCUPANT	
CITY OF SOUTHPORT	SOUTHPORT FIRE STATION	
113 W MOORE STREET	1011 N HOWE STREET	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 08/14/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 10/13/2017

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CHIEF DREW

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF SOUTHPORT
113 W MOORE STREET
SOUTHPORT, NC, 28461