



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17249-75-2364
State Number
13203

EQUIPMENT INSPECTED

State Number: 13203	Type of Unit: Passenger	Floor to Floor: G to 3
Capacity: 2000	Manuf: ASHEVILLE	Speed: 100
Landings: 3	Installed: 02/01/1990	Rope Size:
Volts: 480	Complied: 02/01/1990	Entrances: 1
OWNER	OCCUPANT	
ARBORETUM BUILDING	ARBORETUM BUILDING	
100 FREDRICK LAW OLMSTEAD WAY	WESLEY BRANCH RD	
ASHEVILLE, NC, 28806	ASHEVILLE, NC, 28806	

INSPECTION INFORMATION

Inspection Date 09/06/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
2.27.3.3	Place the Phase II Fire Service feature in proper working order.(call cancel button inop.)
8.6.4.9	Clean the car top.
8.6.4.7	Clean the hoistway and hoistway equipment.

Items must be corrected by: 11/05/2017

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lucas Hatchel 828-665-2492

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARBORETUM BUILDING
100 FREDRICK LAW OLMSTEAD WAY
ASHEVILLE, NC, 28806