



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17254-76-165
State Number
19009

EQUIPMENT INSPECTED

State Number: 19009	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3000	Manuf: KONE	Speed: 125
Landings: 3	Installed: 10/18/2000	Rope Size:
Volts: 480	Complied: 10/26/2000	Entrances: 1
OWNER	OCCUPANT	
ASHE CO BOARD OF COMMERCE	ASHE CO GOVERNMENT COMPLEX	
150 GOV'T CIRCLE, STE 2500	150 GOV'T CIRCLE	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 09/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

- 8.6.5.5.1 Where pressure piping, valves, and cylinders use packing glands or seals, they shall be examined and maintained to prevent excessive loss of fluid.
- 2.29.1 Assign identification numbers or letters to the equipment where required. Provide a sign on the elevator room
- 8.6.11.1 Provide a monthly log on the results of the Phase I and Phase II operations.
- 2.26.12 Provide braille where needed. Door open braille missing
- 5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.
- 2.14.7.1.3 Place the in-car emergency lights in working order. The auxillary lighting illumination shall not be less than 2 lx (0.2 fc) measured at any point between 48 in. and 35 in. above the car floor and approximately 12 in. centered horizontally in front o
- 2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 09/21/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: Rodney Hopkins 336-846-5508

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHE CO BOARD OF COMMERCE
150 GOV'T CIRCLE, STE 2500
JEFFERSON, NC, 28640