



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17254-76-4830**  
State Number  
**27084**

#### EQUIPMENT INSPECTED

State Number: <b>27084</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: THYSSEN KRUPP	Speed: 150
Landings: 3	Installed: 01/06/2010	Rope Size: 0
Volts: 480	Complied: 01/06/2010	Entrances: 1
OWNER	OCCUPANT	
ASHE COUNTY	ASHE COUNTY LAW CENTER	
150 GOVERNMENT CIRCLE	140 GOVERNMENT CENTER	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

#### INSPECTION INFORMATION

Inspection Date 09/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

#### VIOLATIONS

- 8.6.4.9 Clean the car top.
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 8.6.5.5.1 Where pressure piping, valves, and cylinders use packing glands or seals, they shall be examined and maintained to prevent excessive loss of fluid.
- 8.6.11.1 Provide a monthly log on the results of the Phase I and Phase II operations.

Items must be corrected by: 11/10/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Rodney Hopkins 336-846-5508

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHE COUNTY  
150 GOVERNMENT CIRCLE  
JEFFERSON, NC, 28640