



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17268-44-5799**  
State Number  
**14616**

EQUIPMENT INSPECTED

State Number: <b>14616</b>	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 12000	Manuf: OTIS	Speed: 75
Landings: 3	Installed: 08/17/1992	Rope Size:
Volts: 480	Complied: 06/16/2003	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSOR	
1911 S. CHURCH ST.	NC HWY 87S	
SMITHFIELD, VA, 23430	TAR HEEL, NC, 28392	

INSPECTION INFORMATION

Inspection Date 09/25/2017	Type Inspection Alteration	Certificate Status Issued	Inspector 44 - Carter	County BLADEN
-------------------------------	-------------------------------	------------------------------	--------------------------	------------------

9

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 10/05/2017

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Shane with TKE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING  
1911 S. CHURCH ST.  
SMITHFIELD, VA, 23430