



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17272-70-0048**  
State Number  
**613**

### EQUIPMENT INSPECTED

State Number: <b>613</b>	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: MONARCH	Speed: 50
Landings: 2	Installed: 12/21/1945	Rope Size: 1/2
Volts: 220	Complied: 06/25/2004	Entrances: 1
OWNER	OCCUPANT	
WILLIAM IVEY	SOUTHERN ANTIQUES & POTTERY/ CLOCK SHOP	
118 S CHURCH ST	118 S CHURCH ST	
ASHEBORO, NC, 27203	ASHEBORO, NC, 27203	

### INSPECTION INFORMATION

Inspection Date 09/29/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

76

### VIOLATIONS

- 8.6.10.2 Keys required for access, operation, inspection, maintenance, repair, and emergency access shall be made available only to qualified elevator personnel.
- 2.27.1.1.1 Place the in-car Emergency Phone in working order.
- 8.6.4.20.1 Provide the 5 year full load test.
- 8.6.1.7.2 Provide the appropriate test tag.

Items must be corrected by: 11/28/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dennis Robbins 336-625-5699

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WILLIAM IVEY  
118 S CHURCH ST  
ASHEBORO, NC, 27203