



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17275-76-1549
State Number
23882

EQUIPMENT INSPECTED

State Number: 23882	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: CEMCO	Speed: 90
Landings: 2	Installed: 12/15/2006	Rope Size: 0
Volts: 240	Complied:	Entrances: 1
OWNER	OCCUPANT	
W JEFFERSON UNITED METHODIST CHURCH	W JEFFERSON UNITED METHODIST CH	
107 W 2ND STREET	107 W 2ND STREET	
WEST JEFFERSON, NC, 28694	WEST JEFFERSON, NC, 28694	

INSPECTION INFORMATION

Inspection Date 10/02/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order. Phone needs to work with the power off

Items must be corrected by: 12/01/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Frances herzog 336-246-5292

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

W JEFFERSON UNITED METHODIST CHURCH
107 W 2ND STREET
WEST JEFFERSON, NC, 28694