



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17278-48-1384
State Number
21563

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 21563 | Type of Unit: Passenger | Floor to Floor: 3 to 2 |
| Capacity: 3500 | Manuf: OTIS | Speed: 150 |
| Landings: 1 | Installed: 05/27/2003 | Rope Size: |
| Volts: 208 | Complied: 06/03/2003 | Entrances: 0 |
| OWNER | OCCUPANT | |
| SEA TRAIL CORPORATION | SEA TRAIL CAMPION #37 | |
| 279 CLUBHOUSE ROAD | 140 AVIAN DR. | |
| SUNSET BEACH, NC, 28468 | SUNSET BEACH, NC, 28468 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date 10/05/2017 | Type Inspection Routine | Certificate Status Re-issued | Inspector 48 - Martin | County BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

| | |
|------------|--|
| 2.27.7.2 | Provide the Phase II Fire Service instruction sign inside the elevator. [2ND YR] |
| 2.27.1.1.1 | Place the in-car Emergency Phone in working order. [2ND YR] |

Items must be corrected by: 11/04/2017

Elevator Name: # 4

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEA TRAIL CORPORATION
279 CLUBHOUSE ROAD
SUNSET BEACH, NC, 28468