



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17278-70-4541
State Number
20248

EQUIPMENT INSPECTED

State Number: 20248	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 150
Landings: 4	Installed: 03/15/2002	Rope Size:
Volts: 480	Complied: 03/15/2002	Entrances: 1
OWNER	OCCUPANT	
RANDOLPH COUNTY	RANDOLPH COUNTY COURT HOUSE	
2212 S. FAYETTEVILLE ST	176 E.SALISBURY ST	
ASHEBORO, NC, 27205	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/05/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

76

VIOLATIONS

Elevator Name: #3 STAFF ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Robert Cross 336-318-9481

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RANDOLPH COUNTY
2212 S. FAYETTEVILLE ST
ASHEBORO, NC, 27205