



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17283-65-1788
State Number
23443

EQUIPMENT INSPECTED

State Number: 23443	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/07/2005	Rope Size:
Volts: 208	Complied: 01/05/2006	Entrances: 1

OWNER

ALLERGY PARTNERS CORP
PO BOX 2407
SKYLAND, NC, 28776

OCCUPANT

1985 HENDESONVILLE RD. LOT 4
1985 HENDERSONVILLE RD
ASHEVILLE, NC, 28803

INSPECTION INFORMATION

Inspection Date 10/10/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

8.6.1.6.5 Provide a class ABC fire extinguisher in the machinery space. The extinguisher is expired and must be serviced.

Items must be corrected by: 12/09/2017

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mandy Holbert 828-687-7450

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLERGY PARTNERS CORP
PO BOX 2407
SKYLAND, NC, 28776