



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17285-48-2151
State Number
19579

EQUIPMENT INSPECTED

State Number: 19579	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 02/05/2001	Rope Size:
Volts: 240	Complied: 02/05/2001	Entrances: 1
OWNER	OCCUPANT	
LAWRENCE COASTAL REAL ESTATE	SOUTH PORT CONDOS BLDG.#1	
5003 O'QUINN BLVD.	606 W BROWN ST	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 10/12/2017	Type Inspection Alteration	Certificate Status Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	-------------------------------	------------------------------	--------------------------	---------------------

10

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Brian [TKE]

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAWRENCE COASTAL REAL ESTATE
5003 O'QUINN BLVD.
SOUTHPORT, NC, 28461