



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17289-70-3494**  
State Number  
**6830**

EQUIPMENT INSPECTED

State Number: <b>6830</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1500	Manuf: S THERN	Speed: 100
Landings: 2	Installed: 10/21/1970	Rope Size:
Volts: 220	Complied: 10/21/1970	Entrances: 1
OWNER	OCCUPANT	
WAYNE PARKER	ALUMIWORKS	
900 N MAIN STREET	900 N MAIN STREET	
RANDLEMAN, NC, 27317	RANDLEMAN, NC, 27317	

INSPECTION INFORMATION

Inspection Date 10/16/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

76

VIOLATIONS

5.1.21.1	Place the car alarm bell in working order. Minimum level of 80 dBA.
8.6.4.7	Remove the water from the pit floor and take steps to prevent its re-entry.
2.14.7.1.2	Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.

Items must be corrected by: 12/15/2017

Elevator Name: PASSENGER ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: wayne Parker 336-799-4200

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WAYNE PARKER  
900 N MAIN STREET  
RANDLEMAN, NC, 27317