



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17289-70-5381
State Number
24092

EQUIPMENT INSPECTED

State Number: 24092	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 05/30/2006	Rope Size: 0
Volts: 208	Complied: 05/30/2006	Entrances: 1
OWNER	OCCUPANT	
VICTORY JUNCTION CAMP	VICTORY JUNCTION CAMP	
4500 ADAMS WAY	4500 ADAMS WAY	
RANDLEMAN, NC, 27317	RANDLEMAN, NC, 27317	

INSPECTION INFORMATION

Inspection Date 10/16/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

76

VIOLATIONS

8.6.1.4.1	Provide an updated Firefighters Emergency Operation log. (Monthly)
8.6.5.7	Provide an oil usage log in the machine room.
8.6.11.1	Provide a monthly log on the results of the Phase I and Phase II operations.

Items must be corrected by: 12/15/2017

Elevator Name: ADMIN BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Tracy Hedrick 336-382-0136

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

VICTORY JUNCTION CAMP
4500 ADAMS WAY
RANDLEMAN, NC, 27317